

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 12.02.2024

It is certified that an inspection team headed by

Assistant Executive Engineer (Env)

(Name of Officers with designation) from.....

Jagdish Bhandary PHED

inspected the SRI CHAITANYA TECHNO SCHOOL, opposite to iskon temple, Krishna giri hills, Ashapur road, Raichur – 584101 ,Raichur KARNATAKA on12.02.2024..... (date of inspection) and on the basis of Water Test Report bearing no..... dated.....

Of (PHED Lab) certified that the SRI CHAITANYA TECHNO SCHOOL, opposite to iskon temple, Krishna giri hills, Ashapur road, Raichur – 584101 ,Raichur KARNATAKA has safe drinking water facilities for the students and members of staff of the institution. School is also maintain the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central State/ U.T. Govt.

This certificate is valid till11.02.2025.....

Signature with Seal:

Name

Designation

Name & Address of the Office / Department

12/02/2024
ಪರಿಸರ ಅಭಿವೃದ್ಧಿ ಇಲಾಖೆ
ನಿರೀಕ್ಷಕರ ಕಛೇರಿ

To

Sri Chaitanya Techno School
,opposite to Iskon temple, Krishna
giri Hills, Ashapur Road, Raichur-
584101 ,Karnataka

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



RURAL DRINKING WATER & SANITATION DEPARTMENT, GoK
 RAICHUR DISTRICT WATER QUALITY TESTING LABORATORY - RDWSD
 CELLAR PORTION, PRED PREMISES, RAICHUR, KARNATAKA, INDIA
 E-mail: rdwsdwqmspraichurlab@gmail.com



TEST REPORT

TO, SRI CHAITANYA TECHNO SCHOOL, OPP ISKON TEMPLE, KRISHNAGIRI HILLS ASHAPUR ROAD, RAICHUR ADDRESS OF THE SAMPLE LOCATION : SRI CHAITANYA TECHNO SCHOOL	Report date: 23-04-2024
	Report Number: RAI24APR0001
	Reference: Sample receipt Form(Departmental)
	Sample receipt date: 22-04-2024
	Date of Sample collection: 22-04-2024
	Analysis start date: 23-04-2024
	Analysis completion date: 23-04-2024
	Sample collection protocol: APHA 24 th Edition
Environmental Condition : Temp 25.4°C	
Sample quantity: 1000 mL	

Sample Particulars: DRINKING WATER

Sl.No	Test	Results	Acceptable Limit IS 10500 : 2012 RA:2018	Permissible Limit IS 10500 : 2012 RA:2018	Protocol
-------	------	---------	--	---	----------

Sample Description / Condition : Clear					
1.	Ph value @25° C	6.63	6.5 – 8.5	No relaxation	IS 3025 (Part-11) : 2022
2.	Specific Conductance, µS/cm@ Temp 25° C	218	–	–	IS 3025 (Part-14) : 2013 RA: 2019
3.	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5 & 6):2018
	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part-8) :2023
4.	Colour, Hazen Units	01	5	15	IS 3025 (Part-4) :2021
5.	Turbidity, NTU	0.1	1	5	IS 3025 (Part-10) : 2023
6.	Total Dissolved Solids @ 180°C, mg/l	150	500	2000	IS 3025 (Part-16) : 2023
7.	Alkalinity as CaCO ₃ , mg/l	64	200	600	IS 3025 (Part-23) : 2023
8.	Total Hardness as CaCO ₃ , mg/l	56.05	200	600	IS 3025 (Part-21) : 2009
9.	Calcium as Ca, mg/l	16.02	75	200	IS 3025 (Part-40) : 1991 RA:2019
10.	Magnesium as Mg, mg/l	3.88	30	100	IS 3025 (Part-46) : 2023
11.	Chloride as Cl, mg/l	47.98	250	1000	IS 3025 (Part-32) : 1988 RA:2019
12.	Sulphate as SO ₄ , mg/l	10.0	200	400	IS 3025 (Part-24) :2022
13.	Fluoride as F, mg/l	0.70	1	1.5	APHA 23 rd Edition 4500F:D RA :APHA 24 th Edition
14.	Nitrate as NO ₃ , mg/l	8.0	45	No relaxation	APHA 23 rd Edition 4500-NO3- B RA :APHA 24 th Edition
15.	Iron as Fe, mg/l	0.20	1	No relaxation	IS 3025 (Part-53) : 2003

Remarks: The given sample conforms within the Acceptable limit of IS 10500:2012 RA:2018 Drinking water specification for above Tested physical & chemical parameters only.

Analysed by Senior Analyst / Junior Analyst (sumitra) (chandrika)	Verified By Quality Manager (Mohd. Sadiq)
---	---

Note:

- 1) The above results relate only to the sample tested.
- 2) The report shall not be reproduced except in full without the prior approval of the Quality Manager.
- 3) Traceability: Traceability of measurements is established using CRMs traceable to National/International standards.
- 4) Samples will be discarded after 15 days from the date of report generation.
- 5) Decision rule is applicable as per the procedure mentioned in RDWSD/WQMSP/DR-01.
- 6) Note : BDL-Below Detection Limit. NTU : Nephelometric meter

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. CCD/HS/02/2023-24

Date:12-02-2024

It is certified that an inspection team headed by **Assistant Executive Engineer (Env)** (Name of Officers with designation) from. **Jagdish Bhandary (PHED)** inspected the **SRI CHAITANYA TECHNO SCHOOL, opposite to Iskon temple, Krishna giri hills, Ashapur road, Raichur 584101 ,Raichur KARNATAKA** on 12-02-2024, certified that the **SRI CHAITANYA TECHNO SCHOOL, opposite to Iskon temple, Krishna giri hills, Ashapur road, Raichur 584101 ,Raichur KARNATAKA** safe drinking water facilities for the students and members of staff of the institution. School is also maintain the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central / State/ U.T. Govt.

This Certificate Valid till :**11-02-2025**.

Sd/-

Assistant Executive Engineer (Env)



"TRUE COPY"
[Signature]